
Inductive sensor

NJ2-11-SN





Degree of protection IP68

ATEX-/IECEx-approvals for zone 0/1/20/21 (Ex i)

■ ATEX-/IECEx-approvals for zone 2/22 (Ex ec/tc)













Dimensions



Technical Data


General specifications		
Switching function		Normally closed (NC)
Output type		NAMUR with safety function
Rated operating distance	Sn	2 mm
Installation		flush
Assured operating distance	Sa	0 1.62 mm
Reduction factor r _{Al}		0.4
Reduction factor r _{Cu}		0.3
Reduction factor r ₃₀₄		0.85
Safety Integrity Level (SIL)		up to SIL3 acc. to IEC 61508 Danger! In safety-related applications the sensor must be operated with a qualified fail safe interface from Pepperl+Fuchs, such as KFD2-SH-EX1. Consider the "exida Functional Safety Assessment" document which is available on www.pepperl-fuchs.com as an integral part of this product's documentation.
Output type		2-wire
Nominal ratings		

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"

Release date: 2023-01-27 Date of issue: 2023-01-27 Filename: 70133159_eng.pdf

Technical Data Nominal voltage U_{\circ} 8.2 V (R_i approx. 1 kΩ) Switching frequency 0 ... 3000 Hz yes , with reverse polarity protection diode Suitable for 2:1 technology Current consumption Measuring plate not detected ≥ 3 mA Measuring plate detected ≤ 1 mA Functional safety related parameters Safety Integrity Level (SIL) SIL 3 10660 a $MTTF_d$ 20 a Mission Time (T_M) Diagnostic Coverage (DC) 0 % Compliance with standards and directives Standard conformity **NAMUR** EN 60947-5-6:2000 IEC 60947-5-6:1999 Standards EN 60947-5-2:2007 EN 60947-5-2/A1:2012 IEC 60947-5-2:2007 IEC 60947-5-2 AMD 1:2012 Approvals and certificates IECEx approval IECEx PTB 11.0092X Equipment protection level Ga Equipment protection level Gb IECEx PTB 11.0092X Equipment protection level Gc (ec) IECEx TUR 21.0017X Equipment protection level Da IECEx PTB 11.0092X Equipment protection level Dc (tc) IECEx TUR 21.0018X Equipment protection level Mb IECEx PTB 11.0092X ATEX approval PTB 00 ATEX 2049 X Equipment protection level Ga PTB 00 ATEX 2049 X Equipment protection level Gb Equipment protection level Gc (ec) TÜV 20 ATEX 8523 X PTB 00 ATEX 2049 X Equipment protection level Da TÜV 20 ATEX 8524 X Equipment protection level Dc (tc) **UL** approval cULus Listed, General Purpose **Ordinary Location** E87056 Hazardous Location E501628 Control drawing 116-0454 CCC approval Hazardous Location 2020322315002308 NEPSI approval **NEPSI** certificate GYJ16.1392X TIIS approval on request **Ambient conditions** Ambient temperature -40 ... 100 °C (-40 ... 212 °F) Mechanical specifications Connection type cable Housing material Valox (PBT), black Valox (PBT), black Sensing face IP68 Degree of protection Cable Cable diameter $4.8 \text{ mm} \pm 0.2 \text{ mm}$ Bending radius > 10 x cable diameter Material silicone 0.34 mm² Core cross section

Connection



м	C	~ .		•	$\boldsymbol{\cap}$	P 1		c
А	u	ч.	-		u		—	

	BF 11	Mounting flange, 11 mm
Bones, per	F-KD-Ex2	Terminal module for NAMUR sensors

5 PEPPERL+FUCHS

Application

Danger!

In safety-related applications the sensor must be operated with a qualified fail safe interface from Pepperl+Fuchs, such as KFD2-SH-EX1.

Consider the "exida Functional Safety Assessment" document which is available on www.pepperl-fuchs.com as an integral part of this product's documentation.

4