Inductive sensor

NJ3-18GK-S1N-5M

- Nonferrous targets
- 3 mm flush in ST37 / 1.0037
- Usable up to SIL 3 acc. to IEC 61508
- Degree of protection IP68
- ATEX &IECEX certifications
- ATEX/IECEx Zone 2/22














Dimensions




Technical Data

General specifications		
Switching function		Normally open (NO)
Output type		NAMUR with safety function
Rated operating distance	Sn	3 mm
Installation		flush in mild steel
Assured operating distance	Sa	0 2.4 mm
Actual operating distance	Sr	2.7 3.3 mm typ.
Reduction factor r _{Al}		1
Reduction factor r _{Cu}		1
Reduction factor r ₃₀₄		0
Safety Integrity Level (SIL)		up to SIL3 acc. to IEC 61508 Danger! In safety-related applications the sensor must be operated with a qualified fail safe interface from Pepperl+Fuchs, such as KFD2-SH-EX1. Consider the "exida Functional Safety Assessment" document which is available on www.pepperl-fuchs.com as an integral part of this product's documentation.
Output type		2-wire
Nominal ratings		
Nominal voltage	U_{\circ}	8.2 V (R _i approx. 1 kΩ)
Switching frequency	f	0 200 Hz

Release date: 2023-01-27 Date of issue: 2023-01-27 Filename: 70133168_eng.pdf

Technical Data Current consumption Measuring plate not detected ≤ 1 mA Measuring plate detected ≥ 3 mA Functional safety related parameters Safety Integrity Level (SIL) SIL 3 MTTF_d 10660 a Mission Time (T_M) 20 a Diagnostic Coverage (DC) 0 % Compliance with standards and directives Standard conformity Standards EN 60947-5-2:2007 EN 60947-5-2/A1:2012 IEC 60947-5-2:2007 IEC 60947-5-2 AMD 1:2012 Approvals and certificates IECEx approval Equipment protection level Ga IECEx PTB 11.0092X IECEx PTB 11.0092X Equipment protection level Gb Equipment protection level Gc (ec) **IECEx TUR 21.0017X** Equipment protection level Da IECEx PTB 11.0092X Equipment protection level Dc (tc) **IECEx TUR 21.0018X** Equipment protection level Mb IECEx PTB 11.0092X ATEX approval Equipment protection level Ga PTB 00 ATEX 2049 X PTB 00 ATEX 2049 X Equipment protection level Gb Equipment protection level Gc (ec) TÜV 20 ATEX 8523 X PTB 00 ATEX 2049 X Equipment protection level Da Equipment protection level Dc (tc) TÜV 20 ATEX 8524 X **UL** approval cULus Listed, General Purpose **Ordinary Location** E87056 Hazardous Location E501628 Control drawing 116-0454 CCC approval 2020322315002308 Hazardous Location NEPSI approval **NEPSI** certificate GYJ16.1392X **Ambient conditions** -25 ... 100 °C (-13 ... 212 °F) Ambient temperature Mechanical specifications cable Connection type Crastin (PBT), black Housing material Sensing face Crastin (PBT), black IP68 Degree of protection Cable Cable diameter $6.8 \text{ mm} \pm 0.2 \text{ mm}$ Bending radius > 10 x cable diameter Material silicone Core cross section 0.75 mm² Length L Note only for non-ferrous metal **General information** Use in the hazardous area see instruction manuals

Connection



Accessories



BF 18

Mounting flange, 18 mm

Application

Danger!

In safety-related applications the sensor must be operated with a qualified fail safe interface from Pepperl+Fuchs, such as KFD2-SH-EX1.

Consider the "exida Functional Safety Assessment" document which is available on www.pepperl-fuchs.com as an integral part of this product's documentation.